

SPEL Bio

Bioretention filter media



spelstormwater
joy in water

spel.com.au



SPELBio media is a highly advanced stormwater filtration system and growing media.

SPELBio Bioretention Filter Media helps plants establish quickly.

It can be used in standard catch basin structures, rain gardens, bioretention cells and pre-fabricated structures such as SPELVault concrete tanks.

APPLICATIONS

- Commercial
- Industrial
- Residential

FEATURES

- Organic matter source includes mature compost made in general accordance with MRTS Form G Standard
- Optimal Total Dissolved Salts (EC) for establishing plants and supporting growth
- Made in general accordance with CRC for Water Sensitive Cities Appendix C: Guidelines for filter media in stormwater biofiltration systems (Version 4.01) - July 2015

BENEFITS

- Removal of excess nutrients - i.e. NPK
- Growing media supports plant establishment
- Low nitrogen and phosphorus content

SPECIFICATIONS

CHEMICAL PROPERTIES	TEST METHOD	INDICATIVE SPEL RANGE	FAWB RECOMMENDATIONS
Organic Matter (%)	**Calculation - Total Carbon x 1.7	2.0 – 2.6	<5
pH in H2O (1:5) (pH unit)	AS4419 – 2003	7.46 - 7.59	5.5-7.5
Electrical Conductivity in H2O (1:5) (dS/m)	AS4419 – 2003	0.23 – 0.26	<1.2
Total Nitrogen (mg/kg)	Inhouse S4a (LECO Trumac Analyser)	430 - 815	<1000
Available Phosphate (mg/kg)	** Rayment & Lyons 2011 - 9B2 (Colwell)	72.2 – 85.3	<80
PARTICLE SIZE DISTRIBUTION (PSD)			
Gravel (> 5.0 mm) (%)		2.21	
Gravel (3.5-5.0 mm) (%)		4.17	
Fine Gravel (2.0-3.4 mm) (%)	ASTM		
F1632-03 (2010)	15.67	<3	
Very Coarse Sand (1.0-2.0 mm) (%)		27.43	0-10
Coarse Sand (0.5-1.0 mm) (%)		31.88	< 25
Medium Sand (0.25-0.5 mm) (%)		12.82	40-60
Fine Sand (0.15-0.25 mm) (%)		3.35	10-30
Very Fine Sand (0.05-0.15 mm) (%)		1.82	5-30
Clay & Silt (<0.05 mm) (%)		0.66	< 3
PHYSICAL CHARACTERISTICS			
Saturated Hydraulic Conductivity (Ksat) (mm/hr)	ASTM F1815-11	308 - 329	100-300
D Values			
D15		0.43	
D85		2.63	

SPELBio

Bioretention filter media

<p>NSW HEAD OFFICE 100 Silverwater Rd, Silverwater NSW 2128 PO Box 7138, Silverwater NSW 1811 P: +61 2 8705 0255 P: 1300 773 500 E: nsw.sales@spel.com.au</p>	<p>QLD MAIN OFFICE 130 Sandstone Pl, Parkinson QLD 4115 P: +61 7 3271 6960 P: 1300 773 500 E: qld.sales@spel.com.au</p> <p>QLD SUNSHINE COAST BRANCH 19-27 Fred Chaplin Circuit, Bells Creek, QLD 4551 P: 1300 773 500 E: qld.sales@spel.com.au</p>	<p>VIC & TAS OFFICE 897 Wellington Rd Rowville VIC 3178 P: +61 3 5274 1336 P: 1800 810 139 E: sales@spel.com.au</p> <p>VIC GEELONG BRANCH 70 Technology Close, Corio, P: +61 3 5274 1336 P: 1800 810 139 E: sales@spel.com.au</p>
<p>SA OFFICE 9 Hampden Road, Mount Barker SA 5251 P: 1300 773 500 E: sales@spel.com.au</p>	<p>WA OFFICE 2 Modal Crescent Canning Vale WA 6155 P: +61 8 9350 1000 P: 1800 335 550 E: sales@spel.com.au</p>	<p>NZ OFFICE AUCKLAND 100 Montgomerie Road Airport Oaks P: +64 9 276 9045 E: sales@spel.com.au</p>
<p>NZ OFFICE WANGANUI 43 Heads Road Wanganu New Zealand P: +64 6 349 0088 E: sales@spel.com.au</p>	<p>NZ OFFICE WELLINGTON 41 Raiha St Porirua Wellington New Zealand P: +64 4 239 6006 E: sales@spel.com.au</p>	<p>PHILIPPINES OFFICE METRO MANILA Unit 2210 Lumiere Residences Pasig Boulevard, Pasig City P: +61 2 8705 0255 P: 1300 773 500 E: sales@spel.com.au</p>
<p>SINGAPORE OFFICE 512 Chai Chee Lane, #06-04 Bedok Industrial Estate, Singapore 469028 P: +61 2 8705 0255 P: 1300 773 500 E: sales@spel.com.au</p>	<p>UK OFFICE UNITED KINGDOM Lancaster Rd Shrewsbury SY1 3NQ UK P: +44 (0)1743 445200 E: sales@spel.com.au</p>	<p>USA OFFICE CLEVELAND 4548 Industrial Parkway Cleveland, Ohio 44135 P: +61 2 8705 0255 P: 1300 773 500 E: sales@spel.com.au</p>

We believe clean water is a right not a privilege and we work to ensure a joy in water experience for you with your children and grandchildren.



spelstormwater
joy in water

100 Silverwater Rd, Silverwater NSW 2128 Australia

Phone: (02) 8705 0255

Email: sales@spel.com.au

spel.com.au

SPEL Stormwater accepts no responsibility for any loss or damage resulting from any person acting on this information. The details and dimensions contained in this document may change, please check with SPEL Stormwater for confirmation of current specifications.